Energy Savings



Plug in to Cost Containment Measures


A long, long time ago (1996)

- Every UCA building had its own chiller
- Inefficient and inappropriately sized lighting fixtures wasted electricity.
- Oversized and obsolete boilers wasted gas.
- Little attention was given to reducing water waste.
- Much HVAC equipment used archaic controls, which wasted energy and made diagnosing equipment failures difficult.


Today (2013)

- District Cooling connects state of the art cooling equipment to almost every building on campus.
- Replacing/Retrofitting light fixtures is cutting power demand as much as 70% for lighting
- Replacing old hot water and steam boilers has produced dramatic reductions in gas energy use.
- Aerators installed by CenterPoint free of charge are reducing water and energy use.
- Sophisticated digital controls now operate almost all HVAC equipment, saving energy and increasing comfort.
- Etc!

Meet your District Cooling System



Chilled Water Plants



The main chilled water plants are at Farris Center (700 tons), West Plant (1600 tons), and South Plant (700 tons).

Located at the West Chiller Plant, the newest chiller (800 ton) is the most efficient available. It uses less than 50% as much energy as our oldest chillers.



Why plug into a District Cooling Loop?

- Heating and Air Conditioning our buildings accounts for as much 84% of the energy use.
- Chillers on the loop were chosen for their high efficiency.
- Connecting a building to the loop requires considerably less up front capital.
- The loop is a more reliable source of cooling than a sole chiller in a building.

Upgrade to Efficient Boilers

- <u>Bernard Hall-</u>Replaced steam boiler with more efficient hot water boilers.
- <u>Doyne Health Science</u> Replaced obsolete steam boiler with modular condensing hot water system
- <u>Harrin</u> Installed high efficiency condensing boiler
- <u>Lewis Science</u> Replaced large obsolete steam boiler with modular hot water boiler system.
- <u>Mashburn</u> –replaced obsolete steam boiler system with high efficiency hot water system
- <u>Baridon</u> Installed high efficiency condensing boilers.
- McCastlain Installed high efficiency condensing boiler system.
- Old Main-Installed high efficiency condensing boiler system.
- <u>President's Place</u> Replaced inefficient boiler heating with modern high efficiency gas furnaces.
- <u>Prince Center</u> Replaced all boilers with more efficient multi-stage boilers

Solar Panels at Christian Cafe

- A \$12,000 grant from SGA funded solar hot water heaters that preheat water for cleaning dishes, etc.
- This saves us about 1000 therms of energy a year or \$1000



Tankless Water Heaters




- College Square Tankless water heaters provide both building heat and domestic hot water for faucets and showers, saving thousands of dollars a year.
- <u>Schichtl</u> Four Tankless heaters replaced a single worn-out boiler.
- Conway and New Hall –
 Tankless water Heaters now heat water for sinks and showers.

Condensing Heaters can save 20-25% in energy!


Ferguson Chapel LEDs



Old Main Ida Waldron Auditorium



Snow Fine Arts Recital Hall





Aerators are installed campus wide in buildings where water is heated with natural gas

Fan Coil Units



Laney Fume Hoods



NON-E&G/OTHER BUILDINGS TOTAL ENERGY USE (1000s of BTUs per SF) *Shown for Info Only—not counted in UCA's Totals


	2007	2012	Change
Christian	317	290	-9%
AETN*	81	108	+34%
Estes Stadium	79	80	+1%
Pepsi Indoor Practice	26	35	+34%
HPER	45	37	-18%
Student Center	95	87	-8%
Non-E&G, Non-dorm Totals	88	89	2%

RESIDENCE HALLS TOTAL ENERGY USE

(1000s of BTUs per Square Foot)
*Only 4 months data in 2012

	2007	2012	Change	2007 Rank	2012 Rank
Arkansas Hall	89	73	-18%	12	11
Baridon Hall	75	61	-18%	10	7
Bear Hall *	•	21		-	1
Bernard East (Dorm)	75	75	0%	9	12
Carmichael	74	71	-4%	7	10
Conway Hall	68	61	-10%	6	6
Farris, Jr	51	45	-13%	3	2
Hughes	63	63	0%	5	8
Minton Hall	74			8	13
New Hall	42	52	+23%	1	3
Short/Denny Halls	58	52	-11%	4	4
Stadium Park	49	55	+12%	2	5
State Hall	85	69	-19%	11	9
Residence Hall Totals	53	49	-8%		


Non E&G Target




E&G BUILDINGS TOTAL ENERGY USE IN 1000s BTUs per Square Foot

	2007	2012	Change	2007	2012
				Rank	Rank
Bernard	62	54	-13%	1	6
Buffalo Hall	72	56	-22%	2	7
Burdick	78	75	-4%	3	18
College of Business		47			1
Conference Center	86	84	-2%	4	23
Farris	132	80	-39%	5	21
Harrin	113	96	-14%	6	25
Health Sciences & Meador	75	64	-14%	7	12
Irby	80	89	+11%	8	24
Laney	94	108	+14%	9	27
Lewis	88	74	-16%	10	15
Library	70	62	-12%	11	10
Mashburn	66	54	-18%	12	5
Mass Communications	60	58	-2%	13	8
Math Tech	57	50	-12%	14	4
McAlister	107	73	-32%	15	14
McCastlain	72	75	+4%	16	17
Prince Center	78	83	+7%	17	22
Old Main	103	75	-28%	18	16
Physical Plant	57	49	-13%	19	3
Physical Therapy	82	101	+23%	20	26
Reynolds	73	69	-5%	21	13
Schichtl	117	76	-35%	22	19
Snow Fine Arts	77	60	-22%	23	9
Speech Path	93	77	-18%	24	20
Thompson Hall	36	49	+35%	25	2
Wingo Admin	61	63	+2%	26	11
E & G Subtotals	77	69	-10%		


E&G Target



Total Campus Target



Electric Consumption



Gas Consumption

